

Office of Sub Divisional Engineer, W/S & Sanitation Sub Division No. 2, Sri  
Muktsar Sahib

---


No. 235

Dated: 07/05/24

"WATER SUPPLY CERTIFICATE"

It is certified that water sample letter no. IIS/179/24-25 dated 30-04-2024  
ICONIC INTERNATIONAL SCHOOL Village Rupana, Malout Road District Sri Muktsar Sahib  
given for test was gone In the official laboratory of this office, The water was checked  
through chemical tests and according to the report, the chemical tests were found to be  
correct. In addition, other residual water (Bacteralalyical) bacteria Tests to be conducted at  
Mohali lab.

**Note: This Certificate is valid for only one year 2024-25.**

  
Sub Divisional Engineer,  
W/S & Sanitation Sub Div 2,  
Sri Muktsar Sahib

ਦਫਤਰ ਉਪ ਮੰਡਲ ਇੰਜੀਨੀਅਰ, ਜਲ ਸਪਲਾਈ ਅਤੇ ਸੈਨੀਟੇਸ਼ਨ, ਉਪ  
ਮੰਡਲ ਨੰ.6, ਸ਼੍ਰੀ ਮੁਕਤਸਰ ਸਾਹਿਬ।

SANITATION CERTIFICATE

Date 07-05-24

This to be Certify that the Sanitation Conditions at  
ICONIC INTERNATIONAL SCHOOL, MALOUT ROAD, SRI  
MUKTSAR SAHIB have been inspected and found to be satisfactory,  
meeting the required standards for healthy & safe environment.

  
ਉਪ ਮੰਡਲ ਇੰਜੀਨੀਅਰ,  
ਜ/ਸ ਤੇ ਸੈਨੀਟੇਸ਼ਨ ਉਪ ਮੰਡਲ ਨੰ. 6  
ਸ਼੍ਰੀ ਮੁਕਤਸਰ ਸਾਹਿਬ

**DISTRICT WATER TESTING LABORATORY, SH. MUKTSAR SAHIB**

Water Supply and Sanitation Department, Division no 1, kotkapoora road near vishal mega Mart ,Distt Muktsar ,Pin  
code 152026  
dwtlmks@gmail.com

To,

Iconic International School  
Rupana


No.: DWTL/MKS/2425/00069 Dated : 03/05/2024

Subject : Testing Reports of Water Samples.

Reference: Your Letter/SRF No. 179 Dated: 30/04/2024

As per above cited subject and reference, Please find enclosed here with the report of 1 Water sample/s received on dated 02/05/2024. It is request to fill the attached feedback form and send it back to District Water Testing Laboratory, Sh. Muktsar Sahib

D/A : Test Report



Authorized Signatory  
For, District Water Testing Laboratory  
Sh. Muktsar Sahib

# DISTRICT WATER TESTING LABORATORY, SH. MUKTSAR SAHIB

Water Supply and Sanitation Department, Division no 1, kotkapoora road near vishal mega Mart ,Distt Muktsar ,Pin  
code 152026  
dwtlmks@gmail.com

## TEST REPORT

Name & Address of Customer : Iconic International School Rupana	Customer Reference No. No : 179 Dated : 30/04/2024	Sample Submitted by principal
	Date of Sample Receipt 02/05/2024	Analysis Starting Date 02/05/2024
	Analysis completion Date 03/05/2024	
Discipline : Chemical Testing	Group: Water	
UIR No.:	Sample Type : Treated Water	
Test Report No.: DWTL/MKS/2425/00069	Date of Issue : 03/05/2024	
Registration no.: DWTL/MKS/REG2425/00069	Condition of Sample : Sealed	
Collection Point: Treatment Plant (RO/CWPP/ARP/HH Purifier)	Quantity/Type of Bottle: 1000 ml / Amber Colored Glass Bottle	
Scheme/Source: Not Mentioned(Not Mentioned)	Location/Depth : rupana muktsar / NA	
Village : Rupana	Habitation : Rupana	
Block: Muktsar	District : Muktsar	
Latitude : Not Mentioned	Longitude: Not Mentioned	

As per IS-10500:2012 (2nd Rev.)

Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	6.78	6.5-8.5	No Relaxation		IS 3025 (Part 11: 2022) Electrometric Method
2	Colour	1	5	15	CU	IS 3025 (Part 4: 2021) Visual Comparison Method
3	Odour	agreeable	Agreeable	Agreeable		IS 3025 (Part 5: 2018) (Second Revision)
4	Taste	agreeable	Agreeable	Agreeable		IS 3025 (Part 8: 2023)
5	TDS	80	500	2000	mg/l	IS 3025 (Part 16: 2023) Gravimetric Method
6	Turbidity	0.6	1	5	NTU	IS 3025 (Part 10: 2023) Nephelometric Method
7	Alkalinity(CaCO3)	57	200	600	mg/l	IS 3025 (Part 73: 2023) Indicator Method
8	Hardness(CaCO3)	56	200	600	mg/l	IS 3025 (Part 21: 2009)(RA 2019) EDTA Method
9	Calcium(Ca)	17	75	200	mg/l	IS 3025 (Part 40: 1991) EDTA Titrimetric Method
10	Magnesium(Mg)	6	30	100	mg/l	APHA (24th Ed. 2023) Method: 3500-Mg+2 B By Calculation Method
11	Chloride(Cl)	20	250	1000	mg/l	IS 3025 (Part 37: 1988) Argentometric Method

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used be as evidence in court of law.
4. Abbreviation used (TDS - Total Dissolved Solids, mg/l - milligram per liter, BDL - Below detection limit, APHA - American Public Health Association, IS - Indian Standard, NT - Not Tested, NA - Not Applicable, NTU - Nephelometric Turbidity Unit, RA - Reaffirmed, ND - Not Detected)
5. \* Value not available or test not performed for this parameter.
6. Temperature condition limit: 25±5°C and Humidity condition limit: 50 ±20%

Reviewed and Approved By

*Ashish Kumar*

Ashish Kumar  
Sr. Chemist  
Authorized Signatory  
For, District Water Testing Laboratory  
Sh. Muktsar Sahib

----- End of the Test Report -----

**DISTRICT WATER TESTING LABORATORY, SH. MUKTSAR SAHIB**

Water Supply and Sanitation Department, Division no 1, kotkapoora road near vishal mega Mart ,Distt Muktsar ,Pin code 152026  
dwtlmks@gmail.com

**INVOICE**

Bill No. : INV/2425/00069

Date. : 02/05/2024

To,

Iconic International School  
Rupana

Ref. : Letter No. 179 Dt. 30/04/2024

Sample Receiving No. DWTL/MKS/R2425/00069 Dt.  
02/05/2024

Sr. No.	Name of Scheme / Source / Location	Nature of Sample	Category Name	Test Parameter	No. of Sample	Rate Per Parameter/ Set of Parameters	Net Amount
1	Rupana, rupana muktsar	Treated Water	Private Schools	Basic Chemical : pH, Colour, Odour, Taste, TDS, Turbidity, Alkalinity, Hardness, Calcium, Magnesium, Chloride	1	130.00	130.00
<b>Total</b>							<b>130.00</b>

One Hundred Thirty Only.

STR No. : NA

Payment Mode : Cash

Payment Status : PAID

Note: \* Discount applicable as per Government Notification Number : No 9784 & Date : 09/11/2021

Authorised Signatory